

Government of Bihar
Public Health Engineering Department
District Level Water Testing Laboratory:- Siwan

Sample Collected by- D.V.M Global School, Papaur

Sample Receiving date:-10.04.2024

Sample Receiving date:-10.04.2024

Sl No.	Date Of Testing	Block	Panchyat	Ward	Name of Scheme	Parameters														
						pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	As	Total Coli
1	12.04.2024	Pachrukhi	Papaur	—	D.V.M Global School, Papaur	6.62	0.6	333.3	194	70.6	18.8	5.6	49.4	69.3	BDL	BDL	BDL	BDL	0.00	<1.1
IS: 10500:2012 (2nd Revision)						6.5-8.5	1.0	-	200	200	75	30	250	200	0.3	45	200	1.0	0.01	
						Accetable Limit														
						Permissible Limits														
						8.5	5.0	-	500	600	200	100	1000	600	1.0	NR	400	1.5	NR	

M.A.
12/04/2024
Chemist

~~D.L.PCH Division, Siwan~~
District Level Water Testing Lab
P.H Division, Siwan